



P.O. Box 265
Troy MO 63379

6365286137
www.flynn drilling.com

Invoice

| | |
|-----------|-----------|
| Date | Invoice # |
| 4/24/2018 | 9664 |

Bill To

City of West Plains
P.O. Box 710
West Plains, MO 65775

| |
|---------------------------|
| Service Location |
| Minnesota Well Well #9 |

Please check box if address is incorrect or has changed, and indicate change(s) above.

| | |
|--------------------|--------------------|
| Balance Due | \$58,618.89 |
|--------------------|--------------------|

Flynn Drilling Company

Troy MO 63379
PO Box 265

PLEASE DETACH AND RETURN TOP PORTION WITH YOUR PAYMENT.

| | | | |
|-------------|----------|----------------|-----|
| Telephone # | P.O. No. | Project | Rep |
| | | Minnesota Well | |

| Description | Qty | Rate | Amount |
|--|-----|-----------|-----------|
| 62SS1000-5AA S/S Grundfos Pump End <i>additional</i> | 1 | 9,568.00 | 9,568.00 |
| ✓ 100hp 460v 3ph Hitachi Motor | 1 | 11,173.00 | 11,173.00 |
| 5" Galv. Drop Pipe <i>additional</i> | 483 | 28.33 | 13,683.39 |
| 2/0 Flat Jacketed Pump Cable <i>additional</i> | 500 | 11.35 | 5,675.00 |
| 5" S/S Flomatic Check Valves <i>additional</i> | 2 | 1,850.00 | 3,700.00 |
| 5" x 12" S/S Nipples <i>additional</i> | 6 | 215.00 | 1,290.00 |
| Setting Material Complete <i>additional</i> | 1 | 795.00 | 795.00 |
| Discharge Head Rehab Complete <i>additional</i> | 1 | 1,747.00 | 1,747.00 |
| ✓ Televised Underground Survey | 1 | 1,200.00 | 1,200.00 |
| ✓ Per Diem | 3 | 375.00 | 1,125.00 |
| ✓ Labor Complete | 1 | 9,625.00 | 9,625.00 |
| Less Maintenance Discount | 1 | -962.50 | -962.50 |
| <i>#36,458.39 Additional</i> | | | |

Payment is due upon receipt. Accounts not paid within 30 days of the date of the invoice are subject to a 18% APR Finance Charge.

Credit card payments are subject to a 2% convenience fee.

| | |
|---------------------------|-------------|
| Subtotal | \$58,618.89 |
| Sales Tax (8.475%) | \$0.00 |
| Total | \$58,618.89 |
| Payments/Credits | \$0.00 |
| Balance Due | \$58,618.89 |



www.flynnndrilling.com

P.O. Box 265 • Troy MO 63379
 OFFICE: 636.528.6137
 FAX: 636.528.6156

P.O. Box 862 • Rolla, MO 65401
 OFFICE: 573.341.8444
 FAX: 573.341.5353

PUMP INSTALLATION

Date: 4-12-18

Owners Name: City Of West Plains

Jobsite Address: N. Minnesota Ave. GPS: 36.738, -91.863

Well ID: 9

PUMP:

Manufacturer: Grundfos

Model: 625s1000-5AA

Performance: 800 gpm @ 300 tdh @ 3525 rpm

Construction Type: S.S. 8 OD Date Code T51804084HI

Motor:

Manufacturer: Hitachi

HP 100 Volts 480 Phase 3 RPM 3525

Serial Number G2667203H 8 OD Date Code J17C

Running Volts 492 493 492 Running Amps 123 120 118

M-Ohms 50+

Setting Construction:

Depth Setting to Bowl 483

Column Size & Material 5" Galvanized Domestic

Cable Size & Type 2/0 Flat jacket

Check Valve Manufacturer & Type Flomatic VFD S S

Check Valve Locations 462 ft. 231 ft. _____ ft. _____ ft.

Airline Length & Material 494' ft. Of 1/4 poly

Pump Discharge 6 in. X 12 Of S S

Tank Make _____ PSI 5-10

Special Notations _____

Electrical:

Starter Manufacturer Square D 8536 Type ATL Size Nema4

Circuit Protection Type Fuse Size 200

Service Wire Size 2/0 Ground Protection _____

Special Notations _____

Well Information:

Well Depth 1535 ft.

Casing Depth & Size 900 ft. Of 10 in.

Liner Depth & Size _____ ft. Of _____ in.

SWL 94' ft. DD 45 ft. PL 139 ft.

Special Overall Notations _____



