



Missouri Department of Natural Resources

Environmental Services Program  
PO Box 176 Jefferson City MO 65102-0176



RESULTS OF SAMPLE ANALYSES

Test Group:  
Nitrates

Order ID:  
190504385



Report Date:  
6/6/2019

THOMAS J TRIPP  
OZARK DEVELOPMENT CORP  
1910 HOLIDAY LN CITY HALL  
PO BOX 710  
WEST PLAINS MO 65775

<b>Sample: AD48111</b>		<b>Facility ID: MO4181616</b>				
		Site: OZARK DEVELOPMENT CORP		County: HOWELL		
Collect Date: 5/20/2019 8 26 00 AM						
Sample Location: WELL # 1 TREATMENT TP 13675						
Test	Parameter/Method	Result	Units	Qualifier(s)	MCL	SS
Nitrate + Nitrite as N	Nitrate + Nitrite as N/L 10-107-04-1- C	0.54	mg/L		10	

MCL- A Maximum Contaminant Level (MCL) is the legal threshold limit on the amount of a substance that is allowed in drinking water under the Federal Safe Drinking Water Act. MCLs are health based, legally enforceable standards. Drinking water results below the MCLs are considered safe.  
\*Lead and Copper samples have an Action Level (AL) and not an MCL. The AL levels for Lead and Copper are shown in the MCL column.  
SS- Secondary Drinking Water Regulations (secondary standards) are non-enforceable guidelines regulating contaminants that may cause aesthetic effects in drinking water, such as taste, color or odor. It is recommended that water systems comply with secondary standards but water systems are not required to comply.

The analysis of this sample was performed in accordance with procedures approved or recognized by the U. S. Environmental Protection Agency. If you have any questions, please contact Mr. Eric Medlock at (573) 522-5028.

Kevin Thoenen,  
Laboratory Manager  
Environmental Services Program  
Division of Environmental Quality